

What year was the house built?

OR SUBSTANTIALLY RENOVATED
(DEFINED AS A BEDROOM ADDITION OR > 50% OF THE ENTIRE HOUSE
RENOVATED DOWN TO THE WALL STUDS

1. Reminder - House numbers must be on the house
2. Contact cell number noted?
3. Who scheduled apt.?
4. Was fee paid?
5. Date and time of appointment noted?

Prior to 1/1/1975

Smoke detectors:

- On every habitable level
- In the basement
- On the ceiling at the base of every stairway
- On the ceiling outside each separate sleeping area (within 10 feet)
- May be battery powered, or hardwired
- Must be Photoelectric type, (can be in combination with ionization or carbon monoxide)
- Cannot be older than 10 years old
- New or Replacement detectors, must be 10 year sealed battery

Carbon Monoxide Alarms:

- On every level of the home
- Within 10 feet of a bedroom door
- Combination alarms must have voice activation
- May be battery, or hardwired or in combination with a smoke alarm

Between 1/1/1975 and 8/27/1997

Smoke detectors:

- On every habitable level
- In the basement
- On the ceiling at the base of every stairway
- On the ceiling outside each separate sleeping area (within 10 feet)
- Minimum of 1 detector for every 1200 sq ft of living area
- Must be hardwired interconnected
- Must be Photoelectric type, (can be in combination with ionization or carbon monoxide)
- Cannot be older than 10 years old

Carbon Monoxide Alarms:

- On every level of the home
- Within 10 feet of a bedroom door
- Combination alarms must have voice activation
- May be battery, or hardwired or in combination with a smoke alarm

After 8/27/1997

Smoke detectors:

- On every habitable level
- In the basement
- On the ceiling at the base of every stairway
- On the ceiling outside each separate sleeping area (within 10 feet)
- Inside each sleeping area
- Minimum of 1 detector for every 1200 sq ft of living area
- Must be hardwired interconnected with battery back-up
- Must be Photoelectric type, (can be in combination with ionization or carbon monoxide)
- Cannot be older than 10 years old

Carbon Monoxide Alarms:

- On every level of the home
- Within 10 feet of a bedroom door
- Combination alarms must have voice activation
- May be battery, or hardwired or in combination with a smoke alarm

After 1/1/2008

Smoke detectors:

- On every habitable level
- In the basement
- On the ceiling at the base of every stairway
- On the ceiling outside each separate sleeping area (within 10 feet)
- Inside each sleeping area
- Minimum of 1 detector for every 1200 sq ft of living area
- Must be hardwired interconnected with battery back-up
- Must be Photoelectric type, (can be in combination with ionization or carbon monoxide)
- Cannot be older than 10 years old

Carbon Monoxide Alarms:

- On every level of the home
- Within 10 feet of a bedroom door
- Combination alarms must have voice activation
- Must be hardwired and interconnected with battery back-up

Heat Detectors:

- Must have 1 hardwired and interconnected heat alarm in an attached garage